

CROSS CONNECTION CONTROL & BACKFLOW PREVENTION: (a) No owner, consumer, customer or other person hereinafter collectively referred to in this rule and regulation as “person” shall connect, cause to be connected, or allow to remain connected to the water system, or plumbing installation, without the express written consent of the Utility, any piping fixtures, fittings container or appliance in a manner which, under any circumstances, may allow water, wastewater, or any other liquid, chemical or substance, to ingress or egress the water system. (b) Where, in the opinion of the Utility, there may be a risk of contamination to the potable water system, notwithstanding the provisions of subparagraph (a), the Utility may require the customer, at the customer's sole cost and expense, to install at any point on the customer's water service connection or water service pipe, one or more backflow prevention (BFP) devices, which devices shall be of a quality and type approved by the Utility. (c) All BFP devices shall be maintained in good working order. Such devices must be inspected and tested by a certified tester, approved by the Utility, at the expense of the customer. Such inspections shall take place upon installation, and thereafter annually, or more often if required by the Utility. The customer shall submit a report in a form approved by the Utility on any or all tests performed on a BFP device within 30 days of a test. A record card shall be displayed on or adjacent to the BFP device on which the tester shall record the name and address of the owner of the device; the location, type, manufacturer, serial number and size of the device; and the test date, the tester's initials, the tester's name, the name of his employer, and the tester's license number. (d) The Utility shall maintain a program for the issuance, renewal and cancellation of Cross Connection Control Tester's Licenses. The Utility's program shall establish minimum standards, minimum insurance requirements, fees and administrative procedures. (e) Installation, maintenance, field-testing and selection of all BFP devices shall fully conform to the latest revision of CSA B64.10 and CSA B64 series. (f) In the event of any breach, contravention or non-compliance by a person of any of the provision and regulations in a sub-paragraphs (a),(b),(c) or (d) the Utility may: (i) suspend water service to such person, or (ii) give notice to the person to correct the breach, contravention or non-compliance within 96 hours, or a specified lesser period. If the person fails to comply with such notice, the Utility may immediately thereafter suspend water service to such person.